

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units
BACK OFFICE SINK	6/16/2024 04:37	7/15/2024 21:48	70304161001	Lead	3.6	5	ug/L
BACK OFFICE DISP	6/16/2024 04:39	7/15/2024 21:49	70304161002	Lead	<1.0	5	ug/L
BACK OFFICE BATHROOM	6/16/2024 04:40	7/15/2024 21:51	70304161003	Lead	24.5	5	ug/L
BACK WOMENS ROOM SINK	6/16/2024 04:50	7/15/2024 21:52	70304161004	Lead	2.9	5	ug/L
FRONT MEN ROOM SINK	6/16/2024 04:49	7/15/2024 21:54	70304161005	Lead	1.7	5	ug/L
FRONT DRINKING FOUNTAIN	6/16/2024 04:48	7/15/2024 21:55	70304161006	Lead	2.7	5	ug/L
FRONT BREAKROOM DISP	6/16/2024 04:54	7/15/2024 21:57	70304161007	Lead	<1.0	5	ug/L
FRONT BREAKROOM DISP	6/16/2024 04:53	7/15/2024 21:58	70304161008	Lead	<1.0	5	ug/L
MAIN SUPPLY	6/26/2024 07:47	7/15/2024 22:03	70304161009	Lead	<1.0	5	ug/L

NYSDOH Action Level for Lead In Schools of 5 ppb