

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units
FIRST AID ROOM SINK	6/18/2024 05:12	7/16/2024 13:14	70304143001	Lead	1.4	5	ug/L
FIRST AID ROOM ICE MACHINE	6/18/2024 05:13	7/16/2024 13:16	70304143002	Lead	<1.0	5	ug/L
BOY PE COACH BATHROOM	6/18/2024 05:16	7/16/2024 13:17	70304143003	Lead	6.9	5	ug/L
BOY LOCKER ROOM DF LEFT	6/18/2024 05:17	7/16/2024 13:19	70304143004	Lead	2.0	5	ug/L
BOY LOCKER ROOM DF RIGHT	6/18/2024 05:19	7/16/2024 13:21	70304143005	Lead	1.2	5	ug/L
POOL BF	6/18/2024 05:21	7/16/2024 13:22	70304143006	Lead	<1.0	5	ug/L
POOL DF	6/18/2024 05:22	7/16/2024 13:24	70304143007	Lead	<1.0	5	ug/L
POOL OFFICE SINK	6/18/2024 05:24	7/16/2024 13:25	70304143008	Lead	6.4	5	ug/L
CONCESSION SINK	6/18/2024 05:28	7/16/2024 13:33	70304143009	Lead	<1.0	5	ug/L
GYM HALL BF	6/18/2024 05:29	7/16/2024 13:38	70304143010	Lead	<1.0	5	ug/L
GYM HALL DF LEFT	6/18/2024 05:30	7/16/2024 13:43	70304143011	Lead	<1.0	5	ug/L
GYM HALL DF CENTER	6/18/2024 05:31	7/16/2024 13:44	70304143012	Lead	<1.0	5	ug/L
GYM HALL DF RIGHT	6/18/2024 05:31	7/16/2024 13:46	70304143013	Lead	<1.0	5	ug/L
GIRLS PE COACH BATHROOM	6/18/2024 05:35	7/16/2024 13:48	70304143014	Lead	9.8	5	ug/L
ROOM 54 SINK	6/18/2024 05:38	7/16/2024 13:52	70304143015	Lead	1.8	5	ug/L
NURSE EXAM SINK	6/18/2024 05:40	7/16/2024 13:54	70304143016	Lead	1.0	5	ug/L
NURSE BATHROOM SINK	6/18/2024 05:41	7/16/2024 13:56	70304143017	Lead	1.4	5	ug/L
ATHLETE DIR BATHROOM	6/18/2024 05:44	7/16/2024 13:57	70304143018	Lead	3.2	5	ug/L
PT/GT SINK	6/18/2024 05:45	7/16/2024 13:59	70304143019	Lead	<1.0	5	ug/L
G-6 SINK	6/18/2024 05:48	7/16/2024 14:00	70304143020	Lead	<1.0	5	ug/L
CAFETERIA DF	6/18/2024 05:52	7/16/2024 14:02	70304143021	Lead	<1.0	5	ug/L
G-3 SW	6/18/2024 05:55	7/16/2024 14:03	70304143022	Lead	<1.0	5	ug/L
G-3 NW	6/18/2024 05:56	7/16/2024 14:05	70304143023	Lead	<1.0	5	ug/L
G-3 NE	6/18/2024 05:56	7/16/2024 14:07	70304143024	Lead	3.0	5	ug/L
G-3 SE	6/18/2024 05:57	7/16/2024 14:11	70304143025	Lead	1.5	5	ug/L
G-4 SINK	6/18/2024 05:58	7/16/2024 14:13	70304143026	Lead	<1.0	5	ug/L
G-5 SOUTH SINK	6/18/2024 06:01	7/16/2024 14:15	70304143027	Lead	<1.0	5	ug/L
G-5 NORTH SINK	6/18/2024 06:03	7/16/2024 14:16	70304143028	Lead	<1.0	5	ug/L
CUSTODIAL BATHROOM	6/18/2024 06:07	7/16/2024 14:21	70304143029	Lead	6.3	5	ug/L
KITCHEN BATHROOM	6/18/2024 06:09	7/16/2024 14:26	70304143030	Lead	11.8	5	ug/L
POT FILLER	6/18/2024 06:10	7/16/2024 14:34	70304143031	Lead	34.5	5	ug/L
KITCHEN MAIN LEFT	6/18/2024 06:11	7/16/2024 14:35	70304143032	Lead	1.6	5	ug/L
KITCHEN MAIN CENTER	6/18/2024 06:12	7/16/2024 14:37	70304143033	Lead	4.4	5	ug/L
KITCHEN MAIN RIGHT	6/18/2024 06:13	7/16/2024 14:38	70304143034	Lead	1.8	5	ug/L
SERVING WEST SINK	6/18/2024 06:15	7/16/2024 14:40	70304143035	Lead	2.1	5	ug/L
SERVING EAST SINK	6/18/2024 06:16	7/16/2024 14:42	70304143036	Lead	3.2	5	ug/L
1ST FLOOR SE BF	6/18/2024 06:22	7/16/2024 14:43	70304143037	Lead	<1.0	5	ug/L
1ST FLOOR SE DF	6/18/2024 06:23	7/16/2024 14:45	70304143038	Lead	<1.0	5	ug/L
ROOM 113 HALL BF	6/18/2024 06:24	7/16/2024 14:50	70304143039	Lead	<1.0	5	ug/L
ROOM 113 HALL DF	6/18/2024 06:25	7/16/2024 14:51	70304143040	Lead	<1.0	5	ug/L
ROOM 113 HALL N BATHROOM	6/18/2024 06:26	7/16/2024 14:53	70304143041	Lead	1.8	5	ug/L
ROOM 113 HALL S BATHROOM	6/18/2024 06:27	7/16/2024 14:54	70304143042	Lead	2.7	5	ug/L
TEACHERS ROOM SINK LEFT	6/18/2024 06:29	7/16/2024 14:56	70304143043	Lead	12.8	5	ug/L
TEACHERS ROOM SINK RIGHT	6/18/2024 06:30	7/16/2024 14:57	70304143044	Lead	12.7	5	ug/L
ROOM 118 BATHROOM SINK	6/18/2024 06:33	7/16/2024 14:59	70304143045	Lead	1.6	5	ug/L
MAIN OFFICE BATHROOM	6/18/2024 06:34	7/16/2024 15:01	70304143046	Lead	2.5	5	ug/L
1ST FLOOR SW BF	6/18/2024 06:35	7/16/2024 15:02	70304143047	Lead	<1.0	5	ug/L
1ST FLOOR SW DF	6/18/2024 06:36	7/16/2024 15:04	70304143048	Lead	<1.0	5	ug/L
1ST FLOOR WEST BF	6/18/2024 06:38	7/16/2024 17:49	70304143049	Lead	1.2	5	ug/L
1ST FLOOR WEST DF	6/18/2024 06:38	7/16/2024 17:54	70304143050	Lead	1.3	5	ug/L

ROOM 125 SOUTH	6/18/2024 06:41	7/16/2024 17:58	70304143051	Lead	3.2	5	ug/L
ROOM 125 NORTH	6/18/2024 06:42	7/16/2024 18:00	70304143052	Lead	1.6	5	ug/L
ROOM 126 LEFT	6/18/2024 06:44	7/16/2024 18:05	70304143053	Lead	1.8	5	ug/L
ROOM 126 CENTER	6/18/2024 06:45	7/16/2024 18:06	70304143054	Lead	1.3	5	ug/L
ROOM 126 RIGHT	6/18/2024 06:46	7/16/2024 18:08	70304143055	Lead	1.3	5	ug/L
ROOM 127 SINK	6/18/2024 06:48	7/16/2024 18:10	70304143056	Lead	<1.0	5	ug/L
ROOM 146 SINK	6/18/2024 06:51	7/16/2024 18:11	70304143057	Lead	2.5	5	ug/L
ROOM 146 STORAGE	6/18/2024 06:52	7/16/2024 18:13	70304143058	Lead	4.0	5	ug/L
G-17 HALL DF LEFT	6/18/2024 06:55	7/16/2024 18:14	70304143059	Lead	<1.0	5	ug/L
G-17 HALL DF RIGHT	6/18/2024 06:56	7/16/2024 18:16	70304143060	Lead	<1.0	5	ug/L
2ND FLOOR SW BF	6/18/2024 07:00	7/16/2024 18:17	70304143061	Lead	<1.0	5	ug/L
2ND FLOOR SW DF	6/18/2024 07:01	7/16/2024 18:19	70304143062	Lead	<1.0	5	ug/L
2ND FLOOR CENTER HALL BF	6/18/2024 07:04	7/16/2024 18:24	70304143063	Lead	<1.0	5	ug/L
2ND FLOOR CENTER HALL DF	6/18/2024 07:05	7/16/2024 18:25	70304143064	Lead	<1.0	5	ug/L
2ND FLOOR SW BF	6/18/2024 07:07	7/16/2024 18:27	70304143065	Lead	<1.0	5	ug/L
2ND FLOOR SW DF	6/18/2024 07:08	7/16/2024 18:29	70304143066	Lead	<1.0	5	ug/L
2ND FLOOR W BF	6/18/2024 07:09	7/16/2024 18:30	70304143067	Lead	<1.0	5	ug/L
2ND FLOOR W DF	6/18/2024 07:10	7/16/2024 18:32	70304143068	Lead	<1.0	5	ug/L
ROOM 224 TEACHER SINK	6/18/2024 07:12	7/16/2024 18:37	70304143069	Lead	18.3	5	ug/L
ROOM 226 STORAGE	6/18/2024 07:14	7/16/2024 18:44	70304143070	Lead	7.2	5	ug/L
ROOM 226 TEACHER HALL	6/18/2024 07:15	7/16/2024 18:49	70304143071	Lead	2.9	5	ug/L
ROOM 227 SINK	6/18/2024 07:17	7/16/2024 18:51	70304143072	Lead	<1.0	5	ug/L
ROOM 234 SINK TEACHER	6/18/2024 07:19	7/16/2024 18:52	70304143073	Lead	2.9	5	ug/L
ROOM 236 STORAGE	6/18/2024 07:20	7/16/2024 18:54	70304143074	Lead	1.4	5	ug/L
ROOM 236 TEACHER SINK	6/18/2024 07:22	7/16/2024 18:56	70304143075	Lead	2.2	5	ug/L
ROOM 228	6/18/2024 07:24	7/16/2024 18:57	70304143076	Lead	2.2	5	ug/L
ROOM 229 STORAGE	6/18/2024 07:26	7/16/2024 19:02	70304143077	Lead	8.3	5	ug/L
TRACK SW	6/18/2024 07:47	7/16/2024 19:04	70304143078	Lead	2.1	5	ug/L
TRACK NE	6/18/2024 07:50	7/16/2024 19:05	70304143079	Lead	2.2	5	ug/L
TRACK CONESSION KITCHEN	6/18/2024 07:54	7/16/2024 19:07	70304143080	Lead	1.7	5	ug/L
TRACK CONCESSION TRIPLE	6/18/2024 07:56	7/16/2024 19:08	70304143081	Lead	<1.0	5	ug/L
TRACK DF RIGHT	6/18/2024 07:58	7/16/2024 19:10	70304143082	Lead	<1.0	5	ug/L
TRACK DF LEFT	6/18/2024 07:59	7/16/2024 19:11	70304143083	Lead	<1.0	5	ug/L
MAIN SUPPLY	6/18/2024 08:15	7/16/2024 19:13	70304143084	Lead	40.1	5	ug/L
TRACK MENS BATHROOM LEFT	6/18/2024 09:30	7/16/2024 19:15	70304143085	Lead	<1.0	5	ug/L
TRACK MENS BATHROOM CENTER	6/18/2024 09:31	7/16/2024 19:16	70304143086	Lead	<1.0	5	ug/L
TRACK MENS BATHROOM RIGHT	6/18/2024 09:32	7/16/2024 19:21	70304143087	Lead	1.1	5	ug/L
TRACK WOMENS BATHROOM LEFT	6/18/2024 09:33	7/16/2024 19:23	70304143088	Lead	<1.0	5	ug/L
TRACK WOMENS BATHROOM CENTER	6/18/2024 09:34	7/16/2024 19:27	70304143089	Lead	<1.0	5	ug/L
TRACK WOMENS BATHROOM RIGHT	6/18/2024 09:35	7/16/2024 19:32	70304143090	Lead	<1.0	5	ug/L
CAT BF	6/26/2024 06:52	7/16/2024 19:40	70304143091	Lead	<1.0	5	ug/L
ROOM 144 TEACHER SINK	6/26/2024 07:12	7/17/2024 11:22	70304143092	Lead	36.9	5	ug/L
ATHLETIC SUPPLY	6/26/2024 07:18	7/16/2024 19:43	70304143093	Lead	130	5	ug/L

NYSDOH Action Level for Lead In Schools of 5 ppb