

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units
PRINCIPAL BATHROOM	6/16/2024 05:12	7/15/2024 18:08	70304146001	Lead	7.2	5	ug/L
ROOM 370 NURSE	6/16/2024 05:31	7/15/2024 18:09	70304146002	Lead	1.4	5	ug/L
TEACHERS ROOM 303	6/16/2024 05:25	7/15/2024 18:11	70304146003	Lead	3.6	5	ug/L
ROOM 304 ART	6/16/2024 05:27	7/15/2024 18:12	70304146004	Lead	1.1	5	ug/L
ROOM 306 SINK	6/16/2024 05:33	7/15/2024 18:14	70304146005	Lead	5.0	5	ug/L
ROOM 306 DF	6/16/2024 05:35	7/15/2024 18:18	70304146006	Lead	2.4	5	ug/L
ROOM 305 SINK	6/16/2024 05:35	7/15/2024 18:20	70304146007	Lead	1.0	5	ug/L
ROOM 305 DF	6/16/2024 05:37	7/15/2024 18:22	70304146008	Lead	<1.0	5	ug/L
ROOM 302 SINK	6/16/2024 05:40	7/15/2024 18:26	70304146009	Lead	1.7	5	ug/L
ROOM 302 DF	6/16/2024 05:41	7/15/2024 18:31	70304146010	Lead	1.2	5	ug/L
ROOM 104 SINK	6/16/2024 05:56	7/15/2024 18:39	70304146011	Lead	<1.0	5	ug/L
ROOM 104 DF	6/16/2024 05:57	7/15/2024 18:40	70304146012	Lead	<1.0	5	ug/L
ROOM 103 SINK	6/16/2024 05:58	7/15/2024 18:42	70304146013	Lead	<1.0	5	ug/L
ROOM 103 DF	6/16/2024 05:59	7/15/2024 18:43	70304146014	Lead	<1.0	5	ug/L
ROOM 105 SINK	6/16/2024 06:00	7/15/2024 18:45	70304146015	Lead	<1.0	5	ug/L
ROOM 105 DF	6/16/2024 06:01	7/15/2024 18:47	70304146016	Lead	<1.0	5	ug/L
PIT BATHROOM SOUTH	6/16/2024 06:06	7/15/2024 18:48	70304146017	Lead	8.7	5	ug/L
LIB HALL DF	6/16/2024 06:13	7/15/2024 18:50	70304146018	Lead	<1.0	5	ug/L
LIB HALL BF	6/16/2024 06:14	7/15/2024 18:51	70304146019	Lead	<1.0	5	ug/L
ROOM 405 SINK	6/16/2024 05:44	7/15/2024 18:56	70304146020	Lead	4.9	5	ug/L
ROOM 405 DF	6/16/2024 05:45	7/15/2024 18:58	70304146021	Lead	1.0	5	ug/L
ROOM 404 SINK	6/16/2024 05:46	7/15/2024 18:59	70304146022	Lead	<1.0	5	ug/L
ROOM 404 DF	6/16/2024 05:48	7/15/2024 19:01	70304146023	Lead	<1.0	5	ug/L
ROOM 403 SINK	6/16/2024 05:48	7/15/2024 19:02	70304146024	Lead	3.8	5	ug/L
ROOM 403 DF	6/16/2024 05:49	7/15/2024 19:04	70304146025	Lead	<1.0	5	ug/L
ROOM 402 SINK	6/16/2024 05:51	7/15/2024 19:06	70304146026	Lead	2.3	5	ug/L
ROOM 402 DF	6/16/2024 05:52	7/15/2024 19:07	70304146027	Lead	<1.0	5	ug/L
ROOM 106 SINK	6/16/2024 05:53	7/15/2024 19:09	70304146028	Lead	<1.0	5	ug/L
ROOM 106 DF	6/16/2024 05:54	7/15/2024 19:16	70304146029	Lead	<1.0	5	ug/L
LIB HALL MENS SINK	6/16/2024 06:15	7/15/2024 19:21	70304146030	Lead	1.2	5	ug/L
LIB HALL WOMEN N	6/16/2024 06:17	7/15/2024 19:26	70304146031	Lead	<1.0	5	ug/L
LIB HALL WOMEN S	6/16/2024 06:16	7/15/2024 19:27	70304146032	Lead	5.2	5	ug/L
ROOM 517 BATHROOM	6/16/2024 06:21	7/15/2024 19:29	70304146033	Lead	<1.0	5	ug/L
ROOM 517 SINK	6/16/2024 06:22	7/15/2024 19:34	70304146034	Lead	<1.0	5	ug/L
ROOM 517 EXAM 1	6/16/2024 06:23	7/15/2024 19:35	70304146035	Lead	6.2	5	ug/L
ROOM 517 EXAM 2	6/16/2024 06:23	7/15/2024 19:37	70304146036	Lead	<1.0	5	ug/L
ROOM 517 DENTAL	6/16/2024 06:24	7/15/2024 19:38	70304146037	Lead	<1.0	5	ug/L
ROOM 516 SINK	6/16/2024 06:27	7/15/2024 19:40	70304146038	Lead	<1.0	5	ug/L
ROOM 516 DF	6/16/2024 06:28	7/15/2024 19:42	70304146039	Lead	<1.0	5	ug/L
ROOM 515 SINK	6/16/2024 06:30	7/15/2024 19:43	70304146040	Lead	<1.0	5	ug/L
ROOM 515 DF	6/16/2024 06:30	7/15/2024 19:45	70304146041	Lead	<1.0	5	ug/L
ROOM 514 SINK	6/16/2024 06:31	7/15/2024 19:46	70304146042	Lead	<1.0	5	ug/L
ROOM 514 DF	6/16/2024 06:31	7/15/2024 19:48	70304146043	Lead	<1.0	5	ug/L
ROOM 513 SINK	6/16/2024 06:35	7/15/2024 19:53	70304146044	Lead	<1.0	5	ug/L
ROOM 513 DF	6/16/2024 06:35	7/15/2024 19:54	70304146045	Lead	<1.0	5	ug/L
ROOM 512 SINK	6/16/2024 06:37	7/15/2024 19:56	70304146046	Lead	4.1	5	ug/L
ROOM 512 DF	6/16/2024 06:37	7/15/2024 19:57	70304146047	Lead	<1.0	5	ug/L
ROOM 511 SINK	6/16/2024 06:39	7/15/2024 19:59	70304146048	Lead	<1.0	5	ug/L
ROOM 511 DF	6/16/2024 06:40	7/15/2024 20:03	70304146049	Lead	<1.0	5	ug/L
GYM DF	6/16/2024 06:43	7/15/2024 20:11	70304146050	Lead	<1.0	5	ug/L

GYM BF	6/16/2024 06:44	7/15/2024 20:16	70304146051	Lead	<1.0	5	ug/L
ROOM 208 DF	6/16/2024 06:48	7/15/2024 20:17	70304146052	Lead	<1.0	5	ug/L
ROOM 208 SINK	6/16/2024 06:48	7/15/2024 20:19	70304146053	Lead	1.1	5	ug/L
ROOM 207 SINK	6/16/2024 06:49	7/15/2024 20:21	70304146054	Lead	<1.0	5	ug/L
ROOM 207 DF	6/16/2024 06:50	7/15/2024 20:22	70304146056	Lead	<1.0	5	ug/L
ROOM 206 SMLL	6/16/2024 06:51	7/15/2024 20:24	70304146057	Lead	1.3	5	ug/L
ROOM 206 DF	6/16/2024 06:52	7/15/2024 20:25	70304146058	Lead	<1.0	5	ug/L
RECEIVING BATHROOM	6/16/2024 06:54	7/15/2024 20:30	70304146059	Lead	9.6	5	ug/L
KITCHEN SINK	6/16/2024 06:56	7/15/2024 20:31	70304146060	Lead	2.5	5	ug/L
KITCHEN POT FILLER	6/16/2024 06:58	7/15/2024 20:33	70304146061	Lead	5.4	5	ug/L
ROOM 205 SINK	6/16/2024 06:59	7/15/2024 20:35	70304146062	Lead	1.1	5	ug/L
ROOM 205 DF	6/16/2024 07:00	7/15/2024 20:36	70304146063	Lead	<1.0	5	ug/L
ROOM 204 SINK	6/16/2024 07:01	7/15/2024 20:38	70304146064	Lead	<1.0	5	ug/L
ROOM 204 DF	6/16/2024 07:02	7/15/2024 20:39	70304146065	Lead	<1.0	5	ug/L
ROOM 203 SINK	6/16/2024 07:03	7/15/2024 20:41	70304146066	Lead	<1.0	5	ug/L
ROOM 203 DF	6/16/2024 07:04	7/15/2024 20:42	70304146067	Lead	<1.0	5	ug/L
ROOM 202 SINK	6/16/2024 07:05	7/15/2024 20:44	70304146068	Lead	1.2	5	ug/L
ROOM 202 DF	6/16/2024 07:05	7/15/2024 20:49	70304146069	Lead	<1.0	5	ug/L
ROOM 201 SINK	6/16/2024 07:06	7/15/2024 20:53	70304146070	Lead	<1.0	5	ug/L
ROOM 201 DF	6/16/2024 07:07	7/15/2024 20:58	70304146071	Lead	<1.0	5	ug/L
HALLWAY BATHROOM SNIK	6/16/2024 07:05	7/15/2024 21:03	70304146072	Lead	1.3	5	ug/L
CAF GIRLS BATHROOM	6/16/2024 07:11	7/15/2024 21:07	70304146073	Lead	1.0	5	ug/L
CAF BOY BATROOM SINK	6/16/2024 07:12	7/15/2024 21:09	70304146074	Lead	<1.0	5	ug/L
CAF DF	6/16/2024 07:13	7/15/2024 21:10	70304146075	Lead	<1.0	5	ug/L
CAF BF	6/16/2024 07:13	7/15/2024 21:12	70304146076	Lead	<1.0	5	ug/L
ROOM 301 SINK	6/16/2024 07:16	7/15/2024 21:14	70304146077	Lead	<1.0	5	ug/L
ROOM 301 DF	6/16/2024 07:17	7/15/2024 21:15	70304146078	Lead	<1.0	5	ug/L
OUTSIDE SPIGOT 514	6/16/2024 07:27	7/15/2024 21:17	70304146079	Lead	<1.0	5	ug/L
OUTSIDE DF	6/16/2024 07:28	7/15/2024 21:18	70304146080	Lead	64.8	5	ug/L
NORTH PIT SINK	6/16/2024 10:17	7/15/2024 21:20	70304146081	Lead	10.6	5	ug/L
WATER MAIN	6/16/2024 10:25	7/15/2024 21:21	70304146082	Lead	166	5	ug/L

NYSDOH Action Level for Lead In Schools of 5 ppb