

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units
CLASS RM 6	6/13/2024 04:18	7/15/2024 14:00	70304142001	Lead	3.3	5	ug/L
CLASS RM 7	6/13/2024 04:23	7/15/2024 14:02	70304142002	Lead	1.6	5	ug/L
CLASS RM 8	6/13/2024 04:29	7/15/2024 14:03	70304142003	Lead	65.7	5	ug/L
CLASS RM 9	6/13/2024 04:31	7/15/2024 14:05	70304142004	Lead	113	5	ug/L
CLASS RM 10	6/13/2024 04:34	7/15/2024 14:06	70304142005	Lead	12.0	5	ug/L
CLASS RM 12	6/13/2024 04:36	7/15/2024 14:08	70304142006	Lead	14.1	5	ug/L
6TH GRADE HALL DF LEFT	6/13/2024 04:41	7/15/2024 14:09	70304142007	Lead	<1.0	5	ug/L
6TH GRADE HALL DF RIGHT	6/13/2024 04:44	7/15/2024 14:11	70304142008	Lead	<1.0	5	ug/L
6TH GRADE HALL BF	6/13/2024 04:46	7/15/2024 14:16	70304142009	Lead	<1.0	5	ug/L
CL RM 15	6/13/2024 04:48	7/15/2024 14:17	70304142010	Lead	21.8	5	ug/L
CL RM 17	6/13/2024 04:50	7/15/2024 14:19	70304142011	Lead	3.8	5	ug/L
CL RM 16	6/13/2024 04:51	7/15/2024 14:24	70304142012	Lead	32.1	5	ug/L
RM 18 NW SINK	6/13/2024 04:57	7/15/2024 14:28	70304142013	Lead	4.3	5	ug/L
DF ACROSS FROM LIBRARY RIGHT	6/13/2024 05:01	7/15/2024 14:36	70304142014	Lead	<1.0	5	ug/L
DF LEFT ACROSS FROM LIBRARY	6/13/2024 04:59	7/15/2024 14:37	70304142015	Lead	<1.0	5	ug/L
BF ACROSS FROM LIBRARY	6/13/2024 05:02	7/15/2024 14:39	70304142016	Lead	<1.0	5	ug/L
LIBRARY	6/13/2024 05:05	7/15/2024 14:41	70304142017	Lead	6.2	5	ug/L
CL RM 28 TEACHR SINK	6/13/2024 05:07	7/15/2024 14:42	70304142018	Lead	3.8	5	ug/L
CL RM 28 STORAGE	6/13/2024 05:09	7/15/2024 14:44	70304142019	Lead	16.6	5	ug/L
CL RM30 TEACHER SINK	6/13/2024 05:12	7/15/2024 14:45	70304142020	Lead	5.7	5	ug/L
ROOM 32 STORAGE	6/13/2024 05:15	7/15/2024 14:47	70304142021	Lead	36.8	5	ug/L
CL RM 32 TEACHER SINK	6/13/2024 05:15	7/15/2024 14:48	70304142022	Lead	1.5	5	ug/L
CL RM 33	6/13/2024 05:18	7/15/2024 14:53	70304142023	Lead	13.9	5	ug/L
CL RM 35	6/13/2024 05:29	7/15/2024 14:54	70304142024	Lead	3.2	5	ug/L
CL RM 38	6/13/2024 05:22	7/15/2024 14:56	70304142025	Lead	39.7	5	ug/L
ROOM 40	6/13/2024 05:23	7/15/2024 14:58	70304142026	Lead	25.1	5	ug/L
CL RM 37	6/13/2024 05:26	7/15/2024 14:59	70304142027	Lead	2.2	5	ug/L
BOYS CAF BATHROOM LEFT	6/13/2024 05:29	7/15/2024 15:01	70304142028	Lead	1.1	5	ug/L
GIRLS CAF BATHROOM LEFT	6/13/2024 05:29	7/15/2024 15:02	70304142029	Lead	<1.0	5	ug/L
BOY CAF BATH ROOM RIGHT	6/13/2024 05:30	7/15/2024 15:04	70304142030	Lead	1.1	5	ug/L
GIRLS CAF BATHROOM RIGHT	6/13/2024 05:30	7/15/2024 15:05	70304142031	Lead	1.1	5	ug/L
CAF HALL DF	6/13/2024 05:32	7/15/2024 15:13	70304142032	Lead	<1.0	5	ug/L
CAF HALL BF	6/13/2024 05:33	7/15/2024 15:18	70304142033	Lead	<1.0	5	ug/L
KITCHEN BATHROOM	6/13/2024 05:36	7/15/2024 15:22	70304142034	Lead	<1.0	5	ug/L
POT FLLER	6/13/2024 05:37	7/15/2024 15:24	70304142035	Lead	11.8	5	ug/L
KITCHEN SINK LEFT	6/13/2024 05:38	7/15/2024 15:25	70304142036	Lead	3.9	5	ug/L
KITCHEN SINK CENTER	6/13/2024 05:39	7/16/2024 15:34	70304142037	Lead	270	5	ug/L
KITCHEN SINK RIGHT	6/13/2024 05:41	7/15/2024 15:30	70304142038	Lead	3.2	5	ug/L
CAT DF	6/13/2024 05:46	7/15/2024 15:32	70304142039	Lead	1.6	5	ug/L
CONNECT CARE BREAK ROOM	6/13/2024 05:49	7/15/2024 15:33	70304142040	Lead	9.5	5	ug/L
CONNECT CARE KITCHEN	6/13/2024 05:51	7/15/2024 15:35	70304142041	Lead	<1.0	5	ug/L
CONNECT CARE STORAGE	6/13/2024 05:52	7/15/2024 15:36	70304142042	Lead	<1.0	5	ug/L
CONNECT CARE OFFICE	6/13/2024 05:54	7/15/2024 15:38	70304142043	Lead	5.9	5	ug/L
CONNECT CARE BATHROOM	6/13/2024 05:55	7/15/2024 15:40	70304142044	Lead	<1.0	5	ug/L
CONNECT CARE EXAM	6/13/2024 05:56	7/15/2024 15:41	70304142045	Lead	5.6	5	ug/L
NURSE	6/13/2024 06:02	7/15/2024 15:43	70304142046	Lead	<1.0	5	ug/L
DISTRCT OFFICE KITCHEN	6/13/2024 06:10	7/15/2024 15:44	70304142047	Lead	<1.0	5	ug/L
DISTRCT OFFICE BATHROOM LEFT	6/13/2024 06:13	7/15/2024 15:49	70304142048	Lead	<1.0	5	ug/L
DISTRCT OFFICE BATHROOM RIGHT	6/13/2024 06:14	7/15/2024 15:50	70304142049	Lead	4.6	5	ug/L
CL RM 52	6/13/2024 06:17	7/15/2024 15:52	70304142050	Lead	34.9	5	ug/L

CL RM 53	6/13/2024 06:20	7/15/2024 15:54	70304142051	Lead	7.1	5	ug/L
DIRECT OFFICE HALL DF LEFT	6/13/2024 06:23	7/15/2024 15:55	70304142052	Lead	<1.0	5	ug/L
DIRECT OFFICE HALL DF RIGHT	6/13/2024 06:26	7/15/2024 16:00	70304142053	Lead	<1.0	5	ug/L
DIRECT OFFICE HALL BF	6/13/2024 06:27	7/15/2024 16:08	70304142054	Lead	<1.0	5	ug/L
ROOM 55	6/13/2024 06:27	7/15/2024 16:12	70304142055	Lead	6.8	5	ug/L
ROOM 57	6/13/2024 06:30	7/15/2024 16:14	70304142056	Lead	217	5	ug/L
ROOM 54	6/13/2024 06:32	7/15/2024 16:15	70304142057	Lead	3.4	5	ug/L
ROOM 61 N LEFT	6/13/2024 06:38	7/15/2024 16:17	70304142058	Lead	<1.0	5	ug/L
ROOM 61 N CENTER	6/13/2024 06:39	7/15/2024 16:18	70304142059	Lead	<1.0	5	ug/L
ROOM 61 N RIGHT	6/13/2024 06:40	7/15/2024 16:20	70304142060	Lead	<1.0	5	ug/L
ROOM 61 S LEFT	6/13/2024 06:42	7/15/2024 16:21	70304142061	Lead	1.2	5	ug/L
ROOM 61 S RIGHT	6/13/2024 06:43	7/15/2024 16:26	70304142062	Lead	<1.0	5	ug/L
CL RM 63 SE	6/13/2024 06:36	7/15/2024 16:28	70304142063	Lead	<1.0	5	ug/L
CL RM 63 CENTER EAST	6/13/2024 06:37	7/15/2024 16:29	70304142064	Lead	<1.0	5	ug/L
CL RM 63 CENTER WEST	6/13/2024 06:39	7/15/2024 16:31	70304142065	Lead	<1.0	5	ug/L
CL RM 63 SW	6/13/2024 06:40	7/15/2024 16:32	70304142066	Lead	<1.0	5	ug/L
CL RM 63 NW	6/13/2024 06:42	7/15/2024 16:34	70304142067	Lead	<1.0	5	ug/L
CL RM 63 NE	6/13/2024 06:43	7/15/2024 16:36	70304142068	Lead	<1.0	5	ug/L
CL RM 65 SE	6/13/2024 06:53	7/15/2024 16:37	70304142069	Lead	<1.0	5	ug/L
CL RM 65 NW	6/13/2024 06:50	7/15/2024 16:39	70304142070	Lead	<1.0	5	ug/L
CL RM 65 SW	6/13/2024 06:51	7/15/2024 16:40	70304142071	Lead	<1.0	5	ug/L
CL RM 65 NE	6/13/2024 06:52	7/15/2024 16:45	70304142072	Lead	<1.0	5	ug/L
CL RM 67 SINK	6/13/2024 06:59	7/15/2024 16:50	70304142073	Lead	<1.0	5	ug/L
ROOM 67 ICE MAKER	6/13/2024 07:02	7/15/2024 16:54	70304142074	Lead	<1.0	5	ug/L
TECH BATHROOM EAST	6/13/2024 07:05	7/15/2024 16:59	70304142075	Lead	30.2	5	ug/L
TECH DF	6/13/2024 07:06	7/15/2024 17:04	70304142076	Lead	<1.0	5	ug/L
TECH BF	6/13/2024 07:07	7/15/2024 17:05	70304142077	Lead	<1.0	5	ug/L
ROOM 73 RIGHT	6/13/2024 07:07	7/15/2024 17:07	70304142078	Lead	62.6	5	ug/L
ROOM 73 CENTER	6/13/2024 07:08	7/15/2024 17:08	70304142079	Lead	27.5	5	ug/L
ROOM 73 LEFT	6/13/2024 07:09	7/15/2024 17:10	70304142080	Lead	19.3	5	ug/L
TECH BATHROOM	6/13/2024 07:11	7/15/2024 17:11	70304142081	Lead	7.0	5	ug/L
PE ICE MAKER	6/13/2024 07:20	7/15/2024 17:13	70304142082	Lead	<1.0	5	ug/L
GIRLS PE OFFICE BATHROOM	6/13/2024 07:22	7/15/2024 17:15	70304142083	Lead	2.7	5	ug/L
BOYS PE OFFICE BATHROOM	6/13/2024 07:24	7/15/2024 17:16	70304142084	Lead	<1.0	5	ug/L
GYM DF LEFT	6/13/2024 07:25	7/15/2024 17:18	70304142085	Lead	<1.0	5	ug/L
GYM DF RIGHT	6/13/2024 07:26	7/15/2024 17:22	70304142086	Lead	<1.0	5	ug/L
GYM BF	6/13/2024 07:27	7/15/2024 17:24	70304142087	Lead	<1.0	5	ug/L
BASEMENT DF	6/13/2024 07:30	7/15/2024 17:26	70304142088	Lead	<1.0	5	ug/L
BASEMENT BF	6/13/2024 07:35	7/15/2024 17:27	70304142089	Lead	<1.0	5	ug/L
AUDIL DF LEFT	6/13/2024 07:38	7/15/2024 17:29	70304142090	Lead	<1.0	5	ug/L
GREEN ROOM RIGHT	6/13/2024 07:38	7/15/2024 17:30	70304142091	Lead	<1.0	5	ug/L
AUDIT DF RIGHT	6/13/2024 07:39	7/15/2024 17:32	70304142092	Lead	<1.0	5	ug/L
GREEN ROOM LEFT	6/13/2024 07:39	7/15/2024 17:37	70304142094	Lead	<1.0	5	ug/L
GREEN ROOM BATHROOM	6/13/2024 07:40	7/15/2024 17:44	70304142095	Lead	<1.0	5	ug/L
BAND OFFICE SINK	6/13/2024 07:49	7/15/2024 17:49	70304142096	Lead	5.4	5	ug/L
BAND BATHROOM	6/13/2024 07:51	7/15/2024 17:50	70304142097	Lead	<1.0	5	ug/L
REF LOCKER ROOM LEFT	6/13/2024 07:53	7/15/2024 17:52	70304142098	Lead	15.2	5	ug/L
REF LOCKER ROOM RIGHT	6/13/2024 07:54	7/15/2024 17:54	70304142099	Lead	18.9	5	ug/L
OUTSIDE BATHROOM NORTH	6/13/2024 07:59	7/16/2024 15:36	70304142100	Lead	124	5	ug/L
OUTSIDE BATHROOM SOUTH	6/13/2024 08:00	7/15/2024 17:55	70304142101	Lead	16.5	5	ug/L
CL RM14	6/13/2024 08:19	7/15/2024 18:00	70304142102	Lead	89.9	5	ug/L

MAIN SUPPLY	6/27/2024 07:59	7/15/2024 18:01	70304142103	Lead	<1.0	5	ug/L
CL ROOM 11	6/13/2024 04:37	7/15/2024 18:03	70304142104	Lead	6.4	5	ug/L
CL ROOM 13	6/13/2024 04:39	7/15/2024 18:04	70304142105	Lead	4.4	5	ug/L
ROOM 51	6/13/2024 06:18	7/15/2024 18:06	70304142106	Lead	4.1	5	ug/L

NYSDOH Action Level for Lead In Schools of 5 ppb