

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units
KIT SINK	4/12/2024 06:16	7/16/2024 19:45	70304153001	Lead	<1.0	5	ug/L
KIT POT FILLER	4/12/2024 06:17	7/16/2024 19:46	70304153002	Lead	10.0	5	ug/L
REC SINK	4/12/2024 06:19	7/16/2024 19:48	70304153003	Lead	2.4	5	ug/L
RM 101 SINK	4/12/2024 06:22	7/16/2024 19:49	70304153004	Lead	2.0	5	ug/L
RM 101 DF	4/12/2024 06:23	7/16/2024 19:51	70304153005	Lead	<1.0	5	ug/L
RM 101 BR SINK	4/12/2024 06:25	7/16/2024 19:53	70304153006	Lead	1.2	5	ug/L
RM 102 BR SINK	4/12/2024 06:25	7/16/2024 19:54	70304153007	Lead	25.4	5	ug/L
RM 102 SINK	4/12/2024 06:23	7/16/2024 19:59	70304153008	Lead	2.0	5	ug/L
RM 102 DF	4/12/2024 06:24	7/16/2024 20:01	70304153009	Lead	<1.0	5	ug/L
NURSE BR SINK	4/12/2024 06:26	7/16/2024 20:02	70304153010	Lead	4.7	5	ug/L
NURSE SINK	4/12/2024 06:27	7/16/2024 20:04	70304153011	Lead	31.8	5	ug/L
WOMEN BR SINK	4/12/2024 06:22	7/16/2024 20:05	70304153012	Lead	1.4	5	ug/L
MEN BR SINK	4/12/2024 06:21	7/16/2024 20:07	70304153013	Lead	3.4	5	ug/L
RM 103 SINK	4/12/2024 06:27	7/16/2024 20:09	70304153014	Lead	2.1	5	ug/L
RM 103 DF	4/12/2024 06:29	7/16/2024 20:10	70304153015	Lead	<1.0	5	ug/L
RM 105 DF	4/12/2024 06:30	7/16/2024 20:18	70304153016	Lead	55.8	5	ug/L
RM 105 SINK	4/12/2024 06:30	7/16/2024 20:23	70304153017	Lead	12.2	5	ug/L
HW NXT GANG DF1	4/12/2024 06:42	7/17/2024 11:24	70304153018	Lead	<1.0	5	ug/L
HW NXT GANG DF2	4/12/2024 06:42	7/16/2024 20:29	70304153019	Lead	<1.0	5	ug/L
HW NXT GANG BF	4/12/2024 06:41	7/16/2024 20:31	70304153020	Lead	<1.0	5	ug/L
RM 106 SINK	4/12/2024 06:31	7/16/2024 20:32	70304153021	Lead	1.3	5	ug/L
RM 106 DF	4/12/2024 06:32	7/16/2024 20:37	70304153022	Lead	<1.0	5	ug/L
RM 107 SINK	4/12/2024 06:32	7/16/2024 20:39	70304153023	Lead	1.3	5	ug/L
RM 107 DF	4/12/2024 06:33	7/16/2024 20:40	70304153024	Lead	<1.0	5	ug/L
RM 108 SINK	4/12/2024 06:34	7/16/2024 20:42	70304153025	Lead	<1.0	5	ug/L
RM 108 DF	4/12/2024 06:34	7/16/2024 20:43	70304153026	Lead	<1.0	5	ug/L
SERV RM SINK	4/12/2024 06:37	7/16/2024 20:45	70304153027	Lead	23.5	5	ug/L
RM 202 SINK	4/12/2024 06:39	7/16/2024 20:47	70304153028	Lead	2.6	5	ug/L
RM 201 SINK	4/12/2024 06:38	7/16/2024 20:48	70304153029	Lead	<1.0	5	ug/L
RM 203 SINK	4/12/2024 06:45	7/16/2024 20:50	70304153030	Lead	2.5	5	ug/L
RM 203 DF	4/12/2024 06:45	7/16/2024 20:51	70304153031	Lead	2.7	5	ug/L
RM 204 SINK	4/12/2024 06:47	7/16/2024 20:56	70304153032	Lead	2.1	5	ug/L
RM 204 DF	4/12/2024 06:46	7/16/2024 20:58	70304153033	Lead	2.6	5	ug/L
RM 205 SINK	4/12/2024 06:48	7/16/2024 20:59	70304153034	Lead	2.4	5	ug/L
RM 205 DF	4/12/2024 06:48	7/16/2024 21:01	70304153035	Lead	3.5	5	ug/L
HW NXT RM 203/204 DF	4/12/2024 06:44	7/16/2024 21:06	70304153036	Lead	3.3	5	ug/L
HW 307 BR SINK #1	4/12/2024 06:50	7/16/2024 21:10	70304153037	Lead	1.3	5	ug/L
HW 307 BR SINK #2	4/12/2024 06:50	7/16/2024 21:18	70304153038	Lead	<1.0	5	ug/L
GYM OFFICE BR SINK	4/12/2024 06:52	7/16/2024 21:20	70304153039	Lead	8.0	5	ug/L
HW RM 208 BR SINK #1	4/12/2024 06:54	7/16/2024 21:21	70304153040	Lead	1.5	5	ug/L
HW RM 208 BR SINK #2	4/12/2024 06:53	7/16/2024 21:23	70304153041	Lead	2.0	5	ug/L
TEACHER BR SINK	4/12/2024 06:55	7/16/2024 21:25	70304153042	Lead	1.1	5	ug/L
HW NXT RM 311 BF	4/12/2024 06:56	7/16/2024 21:26	70304153043	Lead	<1.0	5	ug/L
RM 300 SINK	4/12/2024 07:00	7/16/2024 21:28	70304153044	Lead	4.9	5	ug/L
RM 301 SINK	4/12/2024 07:02	7/16/2024 21:29	70304153045	Lead	1.7	5	ug/L
RM 302 SINK	4/12/2024 07:03	7/16/2024 21:34	70304153046	Lead	3.7	5	ug/L
RM 303 SINK	4/12/2024 07:04	7/16/2024 21:36	70304153047	Lead	3.6	5	ug/L
RM 304 SINK	4/12/2024 07:09	7/16/2024 21:37	70304153048	Lead	2.5	5	ug/L
RM 304 DF	4/12/2024 07:09	7/16/2024 21:39	70304153049	Lead	9.3	5	ug/L
RM 305 SINK	4/12/2024 07:08	7/16/2024 21:40	70304153050	Lead	4.6	5	ug/L

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units
ROOM 300 DF	6/21/2024 09:17	7/15/2024 21:28	70304151001	Lead	24.1	5	ug/L
ROOM 301 DF	6/21/2024 09:20	7/15/2024 21:29	70304151002	Lead	1.4	5	ug/L
ROOM 305 DF	6/21/2024 09:22	7/15/2024 21:31	70304151003	Lead	12.1	5	ug/L
ROOM 303 DF	6/21/2024 09:24	7/15/2024 21:32	70304151004	Lead	5.7	5	ug/L
ROOM 202 DF	6/21/2024 09:37	7/15/2024 21:34	70304151005	Lead	1.2	5	ug/L
ROOM 103 BATHROOM SINK	6/21/2024 09:45	7/15/2024 21:35	70304151006	Lead	159	5	ug/L
MAIN SUPPLY ROOM	6/26/2024 08:20	7/15/2024 21:40	70304151007	Lead	40.8	5	ug/L

NYSDOH Action Level for Lead In Schools of 5 ppb